

* TESTING IN PARTS PER TRILLION

* ND = NOT DETECTED

EPA TEST METHOD 537.1	PFOS	PFOA	PFOA + PFOS	PFNA	PFHXS	PFBS	MeFOSAA	ADONA	GenX	E+FOsAA	PFDA	PFDOA	PFHpA	PFHxA	PFTeA	PFTriA	PFUNA	9CI-PF3ONS	11CI-PF3OADS	TOTAL PFAS								
ENTRY POINT 1 WATER PLANT	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND								
ENTRY POINT 2 WELL # 6	ND	ND	ND	ND	1.3	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	1.3								
ENTRY POINT 3 WELL # 7	11	6.2	17.2	1.4	34	4.9	ND	ND	ND	ND	ND	ND	5.9	12	ND	ND	ND	ND	ND	75.4								

EPA HEALTH ADVISORY

EPA TEST METHOD 537 (MOD)	PFOS	PFOA	PFOA + PFOS	PFNA	PFHXS	PFBS	MeFOSAA	ADONA	GenX	E+FOsAA	PFDA	PFDOA	PFHpA	PFHxA	PFTeA	PFTriA	PFUNA	9CI-PF3ONS	11CI-PF3OADS	TOTAL PFAS		PFBA	PFDS	FOSA	PFNS	PFHpS	PFPeA	PFPeS
WELL # 7	11	5	16	2.3	22	4.5	ND	/	ND	ND	ND	ND	4.5	9.3	ND	ND	ND	-	-	58.6		2.8	ND	ND	ND	.98	11	2.3
TUBING HILL 516 FT	12	ND	12	3	21	4.4	ND	/	ND	ND	ND	ND	4.8	12	ND	ND	ND	-	-	57.2		ND	ND	ND	ND	ND	11	ND
TOWN HALL 6,810 FT	6.9	3.2	10.1	1.3	12	3	ND	/	ND	ND	ND	ND	2.9	5.9	ND	ND	ND	-	-	35.2		ND	ND	ND	ND	.47	5.7	1.5
11 HAWN DR. 6,472 FT	ND	ND	ND	ND	1.3	.79	ND	/	ND	ND	ND	ND	ND	.57	ND	ND	ND	-	-	2.66		ND	ND	ND	ND	ND	ND	ND

537 (MOD)
ADDITIONAL COMPOUNDS